




TYREE NZ LIMITED

NZ.B.N. 9429039137081
NZ.C.N. 498479
23a Timberly Road
Mangere
Auckland 2022
O Box 132 247,
Sylvia Park,
Auckland 1644
PHONE +64 9 573 1990
EMAIL: info@tyree.nz

PRODUCT SPECIFICATION



- 1. PRODUCT CODE** BMM37067
- 2. DESCRIPTION** 2 Core 7/1.67 (2.5mmsq) plus 7/1.67 (2.5mmsq) Earth.
P.C.W. V90 PVC Insulated and 5V90 P.V.C. Sheathed. Circular Building Cable
450/750 volt to AS/NZS 5000.2. Oxygen Free Copper. RoHS Compliant.
- 3. CONSTRUCTION**
- 3.1 CONDUCTOR:** 7 strands of 0.67mm nom. Plain Annealed Copper to AS1125 drawn from Class 102 copper to AS1574.
Max. D.C. resistance at 20C: 7.4 ohms / km
- 3.2 INSULATION:** Coloured V90 to AS/NZS 3808.
Nominal Diameter: 3.4 mm
Nominal Wall Thickness: 0.7 mm
- 3.3 LAY UP:** 3 Cores laid up.
ACTIVE 1. Red
NEUTRAL 2. Black
EARTH 3. Lt Green / Yellow
- 3.4 SHEATH:** Coloured P.V.C. type 5V90 to AS/NZS 3808.
Target Diameter: 10 mm
Nominal Wall Thickness: 1.3 mm