



TYREE NZ LIMITED

NZ.B.N. 9429039137081
NZ.C.N. 498479
23a Timberly Road Mangere
Auckland 2022
PO Box 132 247,
Sylvia Park, Auckland 1644
PHONE +64 9 573 1990
EMAIL: info@tyree.nz

PRODUCT SPECIFICATION



1. PRODUCT CODE BMM47067

2. DESCRIPTION 3 Core 7/1.67 (2.5mmsq) plus 7/1.67 (2.5mmsq) Earth.
P.C.W. V90 PVC Insulated and 5V90 P.V.C. Sheathed.
Circular Building Cable .450/750 volt to AS/NZS 5000.2.
Oxygen Free Copper. RoHS Compliant.

3. CONSTRUCTION

3.1 CONDUCTOR: 7 strands of 0.67mm nom. Plain Annealed Copper to AS1125 drawn from Class 102 copper to AS1574.

Max. D.C. resistance at 20C: 7.41 ohms / km

3.2 INSULATION: Coloured V90 to AS/NZS 3808.
Nominal Diameter: 3.4 mm
Nominal Wall Thickness: 0.7 mm

3.3 LAY UP: 4 Cores laid up.

ACTIVE 1. Red 2. White 3. Blue
EARTH 4. Lt Green / Yellow

3.4 SHEATH: Coloured P.V.C. type 5V90 to AS/NZS 3808.
Target Diameter: 10.8 mm
Nominal Wall Thickness: 1.3 mm