



TYREE NZ LIMITED

NZ.B.N. 9429039137081
NZ.C.N. 498479
23a Timberly Road
Mangere
Auckland 2022
PO Box 132 247,
Sylvia Park,
Auckland 1644
PHONE +64 9 573 1990
EMAIL: info@tyree.nz

PRODUCT SPECIFICATION



1. PRODUCT CODE	BAC4705
2. DESCRIPTION	3 Core x 7/0.5 + 7/0.5 Earth (1.5mm ²). P.A.C.W. V90 Insulated and 3V90 P.V.C. Sheathed. Flat Building Cable 450/750 Volt to AS/NZS 5000.2. Oxygen Free Copper. RoHS Compliant PVC. TUV AUTHORISED MARKING: TUV-026882-EA
3. CONSTRUCTION	
3.1 CONDUCTOR:	7 strands of 0.5mm nom. Plain Annealed Copper to AS/NZS 1125 Class 2. Max. D.C. resistance at 20C: 13.6 ohms / km
3.2 INSULATION:	Coloured V90 P.V.C. to AS/NZS 3808. Nominal Diameter: 2.7 mm Nominal Wall Thickness: 0.6 mm
3.3 CORE COLOURS:	1. Black 2. Red 3. Green / Yellow 4. White Laid parallel
3.4 SHEATH:	Coloured 3V90 P.V.C. to AS/NZS 3808. Colour - Blue Flat configuration Nominal Dimensions: 4.6 x 12.7 mm Nominal Wall Thickness: 0.9 mm