



## TYREE NZ LIMITED

NZ.B.N. 9429039137081  
NZ.C.N. 498479  
23a Timberly Road  
Mangere  
Auckland 2022  
PO Box 132 247,  
Sylvia Park,  
Auckland 1644  
PHONE +64 9 573 1990  
EMAIL: info@tyree.nz

### PRODUCT SPECIFICATION



<b>1. PRODUCT CODE</b>	BAC47067
<b>2. DESCRIPTION</b>	3 Core x 7/0.67 + 7/0.67 Earth (2.5mm <sup>2</sup> ). P.A.C.W. V90 Insulated and 3V90 P.V.C. Sheathed. Flat Building Cable 450/750 Volt to AS/NZS 5000.2. Oxygen Free Copper. RoHS Compliant PVC. TUV AUTHORISED MARKING: TUV-026882-EA
<b>3. CONSTRUCTION</b>	
<b>3.1 CONDUCTOR:</b>	7 strands of 0.67mm nom. Plain Annealed Copper to AS/NZS 1125 Class 2.  Max. D.C. resistance at 20C: 7.4 ohms / km
<b>3.2 INSULATION:</b>	Coloured V90 P.V.C. to AS/NZS 3808.  Nominal Diameter: 3.2 mm Nominal Wall Thickness: 0.7 mm
<b>3.3 CORE COLOURS:</b>	1. Black 2. Red 3. Green / Yellow 4. White Laid parallel
<b>3.4 SHEATH:</b>	Coloured 3V90 P.V.C. to AS/NZS 3808. Colour - Blue Flat configuration  Nominal Dimensions: 5.5 x 15.7 mm Nominal Wall Thickness: 1.0 mm

---